

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 27/07/26

It is certified that an inspection team headed by Mr. Asheesh Yadav JE (HQ) & Shubham Garg (S)

(Name of Officers with designation) from

Talikal Vibhag Nagar Nigam Prayagraj PHED inspected

the J.P.S. Public School, Dandupur, Chaka (Name & Address of

the school) on 22/07/26 (date of inspection) and on the basis of Water Test Report

(Attached) bearing no. DW/01/Lab 2026-07/05 dated 27/07/26 of

Talikal Vibhag Nagar Nigam Prayagraj Chemical Analysis Laboratory (PHED Lab)

certified that the J.P.S. Public School, Dandupur (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Three months only

अधिसासी अधिकारी (PHED)
जलकल विभाग

Signature with Seal: Mr. Asheesh Yadav

Name : Mr. Asheesh Yadav

Designation : JE (HQ)

Name & Address of the Office/ Department :

To
J.P.S. Public School,
Dandupur, Chaka, Prayagraj
(Name & Address of the Institution)

Note:-The certificate is to be issued by authorized Officer/PHED Lab/Local bodies.



कार्यालय अधिशासी अभियन्ता (मु०)
जलकल विभाग-नगर निगम प्रयागराज
पत्र सं० २०७ मु०ज०क०वि०
दिनांक २५/०७/२६

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2026-07/05

Date: 27.07.2026

DRINKING WATER ANALYSIS REPORT

1	Name & Address	J.P.S PUBLIC SCHOOL, DANDUPUR, CHAKA, PRAYAGRAJ
2	Sample Collected by	By Party
3	Nature of Sample	DRINKING WATER
4	Date of Sample Collection	22.07.2026
5	Date of Sample Receiving	22.07.2026
6	Date of Analysis Completed	27.07.2026

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	-
3.	Temperature	°C	31.6	-	-
4.	Turbidity	NTU	0.9	5	10
5.	Conductivity at 25°C	µmho/cm	720.0	-	-
CHEMICAL PARAMETERS					
6.	pH	-	6.7	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	NIL	-	-
8.	Dissolved Solids	mg/L	368.0	500	2000
9.	Total Solids	mg/L	368.0	-	-
10.	Total Alkalinity (as CaCO ₃)	mg/L	380.0	200	600
11.	Total Hardness (as CaCO ₃)	mg/L	388.0	200	600
12.	Chlorides (as Cl)	mg/L	76.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	0.2	1.0	1.5
14.	Nitrate (as NO ₃)	mg/L	1.89	45.0	100.0
15.	Iron (Fe)	mg/L	0.2	0.3	1.0
BACTERIOLOGICAL PARAMETERS					
Total Coliform		MPN/100ml	Absent	Absent	-
E. coli		MPN/100ml	Absent	Absent	-
Validity- three months only					

Analyst

JE(HQ)

E.E(HQ)

अधिशासी अभियन्ता (मु०)
जलकल विभाग
नगर निगम-प्रयागराज

- Note:**
1. The above results are related only to the test performed on the sample.
 2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
 3. Sample will be destroyed in the after fifteen days from the date of reporting.